



REQUIREMENTS FOR COOKING AT SPECIAL EVENTS

EVENT NAME: _____

EVENT DATE: _____

1. No cooking is permitted under canopies or in non-approved indoor structures.
2. Cooking devices using propane must have the propane bottle outside the booth and properly secured in an upright position.
3. All fittings and hoses used with propane shall be approved for such use by an approved testing laboratory.
4. Propane shall be limited to the supply on site. There shall be no remote storage area.
5. Propane cylinder size is limited to a 5.76-gallon capacity. (Larger capacity may be allowed only with prior Fire Department approval.)
6. There is a limit of one propane cylinder on site per vendor.
7. Refueling of propane cylinders on site or at other than approved locations is prohibited.
8. You must provide your own fire extinguisher with a minimum of 20BC classification at each booth.
9. A minimum of 3 feet clearance must be provided between the public and the cooking device by a barricade.
10. All cooking devices shall be secure, stable and level.
11. L.A. County Health Department approval shall be obtained for cooking on site.
12. No smoking is permitted within 25 feet of propane cylinder or inside the tent or canopy.
13. All propane connections shall be tested for leakage by performing the manufacturer's recommended testing procedures.

ACKNOWLEDGED AND AGREED:

(Signature)

(Print Company or Farm Name)

PLEASE SIGN TWO COPIES – ONE COPY SHALL REMAIN ON SITE AND THE OTHER COPY FOR FIRE DEPARTMENT RECORDS.